

## **1.0 INTRODUCTION**

Gang Warily has several assistance alarms throughout the building which when activated should notify reception that assistance is required in a certain area. Many of these alarms are now in redundant locations and the ones that are still in use activate different alarm panels that are hidden throughout reception. I would like to have the redundant alarms removed and the remaining ones all wired back to the same control box which is clearly on display at reception.

## **2.0 COST**

Based on the below requirements, Complete Security have estimated the cost of carrying out the work at £800.00 + VAT:

1. Retain the hard wired pull cord in the ground floor accessible toilet. Rewire the disabled wireless pull cord for the shower, back to reception, using existing cable if possible.
2. Remove the radio panic buttons in the Fitness Suite
3. Retain hard wired pull cord in the lower ground floor accessible toilet.
4. Remove the radio panic button in the old sauna.
5. Remove old radio control unit in reception, the redundant grey box below and the old Scantronic alarm keypad.
6. Relocate the pull cord control panel outside of the cupboard so it can be seen clearly.

## **3.0 RECOMMENDATIONS**

That the Council commission Complete Security to carry out the above modifications to our assistance alarm systems at a cost of £800.00 + VAT to be taken from budget 4485/1 Maintenance GW

For more information contact:

Joshua Bond,  
Centre & Sports Development Manager  
02380893603  
joshua.bond@fawley-pc.gov.uk