

1.0 INTRODUCTION

Over the last couple of years, the power unit to the pumping station for wastewater has been intermittently tripping. This had been highlighted as an issue with a pump but servicing had seemed to solve the problem. After the most recent service a pump was removed as it was found to have a burnt motor due to a blockage. We have had the pumping station in situ since 2016 with life expectancy of the pumps to be around 5 years. We are currently running on only one pump, which if that fails, the waste water and soils would back up.

2.0 PROPOSED SOLUTION

To have a new pump installed as a replacement of the broken pump.

3.0 RECOMMENDATIONS

That council agree with the need for both pumps to be operational and monies from reserves used to purchase a new pump and install. Estimated costs £1,289.50+VAT. This can be funded through Open Space Ear Marked Reserves

For more information contact:

Jason Mansbridge
Grounds Manager
07849282342
Jason.mansbridge@fawley-pc.gov.uk